



5130 Riverside Drive • Chino, CA 91710 • 909.628.1201 • www.chino.k12.ca.us

BOARD OF EDUCATION: Andrew Cruz • Christina Gagnier • Irene Hernandez-Blair • James Na • Joe Schaffer • SUPERINTENDENT: Norm Enfield, Ed.D.

August 31, 2021

BID # /PROJECT: Bid #21-22-071
SUBJECT: Addendum #1

The following changes, omissions, and or additions to the Project Manual and/or Drawings shall apply to proposals made for and to the execution of the various parts of the work affected thereby, and all other conditions shall remain the same.

Careful note of the addendum shall be taken by all parties of interest so that the proper allowances may be made in strict accordance with the Addendum, and that all <trades / contractors> shall be fully advised in the performance of the work which will be required of them.

Bidder shall acknowledge receipt of this Addendum in the Space provided on the Bid Form. Failure to do so may subject Bidder to be disqualified.

In case of conflict, this Addendum shall govern.

Answers to RFI's and IDF photos

END OF ADDENDUM #1

Attachments: RFI answers Photos of IDFs

Respectfully submitted,

Anna G. Hamilton
Purchasing Director

Requests for Information Responses:

1. 1. I'm not sure where to run the data lines or CAT 6A cable. Are we to have a home run from each classroom to the IDF? Yes, 2 Cat 6A cables pulled from the nearest IDF and terminated to a patch panel on the IDF side and a wall plate on the classroom side. We also need these data drops tested and the results provided to the district.
2. 2. Would this require underground access and piping? No, there is existing pathway to all classrooms.
3. 3. Can you please verify that the existing conduits have the additional capacity for additional the CAT6A cables? Yes, the expectation is that there is space available in the existing pathway, awarded contractor should verify in the field.

IDF photos on following pages.















